# UNITED NATIONS ENVIRONMENT PROGRAMME INTERNATIONAL INSTITUTE OF REFRIGERATION EUROPEAN ENERGY CENTRE

CENTRO STUDI GALILEO







15th EUROPEAN CONFERENCE
THE LATEST TECHNOLOGY
IN AIR CONDITIONING AND REFRIGERATION INDUSTRY.
7<sup>th</sup>-8<sup>th</sup> June 2013



















## **NATURAL REFRIGERANTS**

## **HEAT PUMPS**

LINE UP OF NATURAL FIVE: NH3 - CO2 - HC - WATER - AIR

**HOT WATER PRODUCTION NH3 HEAT PUMP** 

















# LINE UP OF NATURAL FIVE

























































# FIELD CASE

# HOT WATER PRODUCTION NH3 HEAT PUMP

















## REQUIREMENT

NEED	Produce hot water up to 60°C by NH3 heat pump	
CAPACITY	Hot water consumption: 160 m3/day Period: 5 days/week, 18 to 20hrs/day buffer tanks available: 60m3(hot water)/20m3(energy-boiler vessels) Heat capacity=max.750kW	
MEDIUM	Refrigerant: NH3 - Natural refrigerant (ODP=0 & GWP=0) - Condensing temperature 65°C (28,5 barg) Secondary medium: glycol-water - between NH3 & process	
HEAT SOURCE	Condensor circuit of the central refrigeration plant - HP evaporating temperature 25°C (9,0 barg)	


















#### PRINCIPLE SCHEME




















## **EQUIPMENT**

MODEL		N6	N6HK	
QTY		:	2	
SITE LOCATION				
COUNTRY		GERI	GERMANY	
TOWN		STOF	STORKOW	
REFRIGERANT		N	NH3	
TE	°C	2	25	
TC	°C	6	65	
PS	barg		9	
PD	barg	2	28,5	
RPM	rpm	970	1450	
QC	kW	262	393	
BKW	kW	44	69	
СОР-Н		5.9	5.7	
OPERATING HOURS		25/04	25/04/2013	
KVD1	hrs	99	9900	
KVD2	hrs	95	9562	




















## **UNIT PID**

















## MYCOM

## **UNIT LAYOUT**



Installation date:
October 2010

Operating hours per year ±10.600 hrs

Calculation detail:
POWER DRIVE
Efficiency =
97~98%

DRIVE MOTOR SEVA 280M 90kW  $\cos^{\varphi} = 0.87/0.75$ efficiency = 93,7/93,2 (100%/50% load)


















## **OPERATION STATUS**



## Operating hours

KVD1 9900 hrs KVD2 9562 hrs

Σ 19462 hrs

Power consumption

C1 538881 kWh

C2 479100 kWh

Total 1017981 kWh

Heating production

Total 4928342 kWh

Total COPh: 4,8





















## **OPERATION SAVINGS**

COSTS		GAS BOILER	HEAT PUMP
plant heating capacity	kW	4928342	4928342
total running hours status	hrs		19462
load ratio (average)	%	75	75
efficiency	%	85	
required energy	kWh	7730732	1017981
energy quantity			
o gas	liter	773073	
o electricity	kWh		1017981
COP-heating		0.64	4,84
energy cost			
o gas	€/kWh	0,04	
o electricity	€/kWh		0,15
o total energy cost	€	309229	152697
energy saving	€		156532
	%		50
installation cost	€		300000
operating hours per year	hrs		10600
energy saving per year	€		85381
return of investment	years		3,5

















## **CONCLUSION:**

### **ANNUAL SAVINGS:**

OPERATION 85.381 €
CONDENSOR-WATER 2.244 mW
(2,5m3+ treatment)
NATURAL WASTE HEAT
CONDENSOR

RETURN OF INVESTMENT 3.5 YRS

HIGHER EFFICIENCY THAN COMPARABLE TECHNOLOGIES

LONG LIFE TIME (>25 YEARS)

MAINTENANCE LOW-COST
















## MAYEKAWA NEW STANDARD HIGH STAGE HEAT PUMP





















# HOT WATER PRODUCTION AMMONIA HEAT PUMP

## THANKS FOR YOUR ATTENTION!

SPECIAL THANKS TO:
Kältetechnik Dresen + Bremen
Alfhausen-Germany
www.dresen-kaelte.de

























