

# **NATURAL REFRIGERANTS**

## **NH3 high pressure heat pump**

### **hot water production for district heating**

Jan Boone

MAYEKAWA EUROPE S.A., Leuvensesteenweg 605, 1930 Zaventem, Belgium

Tel. 32-2-757-9075, Fax. 32-2-757-9023

#### **ABSTRACT**

This paper focuses on the natural refrigerants which strongly contribute to the reduction of consumption of fossil fuel and significant reduction of the CO2 emissions.

The different system applications are presented in the 'NATURAL 5 LINE-UP'.

The paper presents the results of operation in the field of NH3 high pressure heat pumps for production of hot water for district heating installations.

The plant uses high pressure reciprocating type compressors.

The heat pump produces hot water at 85°C with capacity of 4.400 kW in the winter by using NH3 as refrigerant at 88°C.

The paper is supported with technical details and photo's of each system.

As closure for the paper a 90 GWh heat pump plant in construction is mentioned for demonstrating the importance of savings in energy needed and CO2 emissions.

## FIELD CASE.

The starting point for the project was to build the heating plant using flue gas waste heat from an industrial plant as heat source.

The new plant with nominal design capacity of 4400 kW hot water of 85°C per hours, is to be used for production of hot water for district heating operation 24 hours per day per workweek in the different seasons : winter(high season), spring and autumn(mid season) and summer(low season).

The choice for NH3 was made as it is the most suitable natural refrigerant.

To produce the water of 85°C : NH3 is needed to condens at 88°C (49,1 bara),

To use the heat source at maximum 50°C : NH3 is needed to evaporate at maximum 47°C (12,8bara), which must be covered by the choice of the compressor.

The NH3 charge was to be kept with 500 kg total for this plant. NH3 is standard application for the contractor. The timeframe for the project was order clearance till October 2016 and installation to be finalised until February 2017. The handing over including site acceptance test was done 21-3-2017.

The system design details are shown in the table nr 1.

The hot water is heated up from 59,5°C to 85°C with capacity 4392 kW, while the heat source side cools the water from the flue gas waste heat exchanger from 50°C to 26°C with capacity of 3646 kW. 3 high pressure piston type compressors model N6HS are installed on each of the units C10, C20 and C30. The drive motors are 400kW for C10 and 315kW for C20/C30. The NH3 charge for per unit is 150kg as individual circuit corresponding with approx. 85g per kW heating output.

Table 1.

SYSTEM DESIGN DETAILS				REF.S078287	
HEAT OUTPUT		HOT WATER FOR DISTRICT HEATING			
		water	outlet	°C	85
			return	°C	59,5
		capacity		kW	4392
HEAT SOURCE		FLUE GAS			
		water	inlet	°C	50
			outlet	°C	26
		capacity		kW	3646
COMPRESSORS		type	high pressure reciprocating		
		model	N6HS		
		quantity	3		
DRIVE MOTORS		power	kW	400	C10
VFD			kW	315	C20
			kW	315	c30
NH3		charge	kg	150	each
			g/kW	85	
		circuit		individual	

Figure 1 explains the system and water flows on heat output side and heat source side.




Figure 1.

Each block shows the individual heat pump unit and NH3 circuit with compressor – condensor – liquid subcooler and evaporator : C10, C20 and C30.

The heat source flow is serial starting from inlet 50°C in C10 via C20 to C30 with 27°C outlet.

The heating flow on the liquid subcoolers inlet 59,5°C goes parallel to the 3 units and is taken with the main water flow to the condensers in serial flow starting from C30 via C20 to C10 with 85°C outlet.

Table 2 shows the design data of the 3 compressors operating in serie in the heat pump installation. Using the compressors with liquid subcooling in serie results in an more optimal COP-heating. The 6 cylinder high pressure, design presssure 66 barg, compressor is operating with variable frequency drive and individual mechanical cylinder control.

DESIGN DATA					
HEAT PUMP		C10	C20	C30	total
TC(PD)	°C(barg)	88(48,1)	79(39,5)	71(32,9)	
TE(PS)	°C(barg)	38(13,7)	30(10,7)	24(8,7)	
SC	°C	24	15	7	
HEATING	kW	1785	1423	1183	4391
BKW	kW	316	264	226	806
COPh		5,65	5,39	5,23	5,45
HEATING WATER					
OUT	°C	85	76	68,5	85
IN	°C	76,1	68,5	61,4	59,5
FLOW	kg/s				41,2
HEAT SOURCE					
IN	°C	50	40,5	32,7	50
OUT	°C	40,5	32,7	26,7	27
FLOW	kg/s				37,9




Table 2.



150 kg NH<sub>3</sub>  
85g/kW

Figure 3.



In table 3 an overview is shown on the COP-h in the high season. The graphs show the COP-h per compressor at different load conditions. The load is given at maximum speed 1450rpm followed by 1300, 1100, 900 and 750 as shown in the table. The last 3 columns show mechanical unload operation at 1, 2 and 3 unloaded cylinders or 83, 66 and 50% loaded cylinders.

4




Table 3.

HEAT PRODUCTION ON YEARLY BASIS										
season	rpm vs hours					heating	BKw		COPh	
	hp	C10	C20	C30	sum	per hour	total	per hour	total	
	rpm	hrs	hrs	hrs	hrs	kW	MWh	kW	MWh	
high 5m	1300	3600	3600	3600	10800	4000	43200	727	7852	5,44
mid 4m	1100	2840	2540	300	5680	2435	13831	430	2442	5,20
low 3m	750	2011	0	311	2322	1229	2854	224	520	5,49
total		8451	6140	4211	18802		59885		10814	5,37

Table 4.

In table nr 4 an overview is given of the heat production of 1 year operation. The seasons are shown in the first column with 5 months operation for high season, 4 months operation for mid season and 3 months for the low season. The next columns show the running hours per season of each compressor and the total running hours per season.

The next columns show heating capacities and compressor shaft powers taken on the lowest operating speeds per season what means 1300rpm for high season, 1100rpm for mid season and 750rpm and cylinder part load for low season.

The COP-h's are taken at the maximum speeds(in red) as they are lower than at reduced speeds. It shows that the final total COP-h becomes 5,37 (instead of 5,55 at lower speed).

The operation savings of this heat pumps compared to conventional gas boilers are listed up in table 5. For the heat pump 20% losses are deducted from the COP-h shown in table 4. ( $5,37 \times 0,8 = 4,3$ ) The yearly hot water production of the heat pump is increased with 10% in case of the gas boiler. The yearly energy consumption in case of the heatpumps is 13.931 MWh while 66.538 MWh for the gas boiler representing a saving of 52.607 MWh or 80% !

The energy prices for the plant are amounting to 90 €/MWh for electricity and 45 €/MWh for gas which results in an energy cost of 1.253.805€ for the heat pump versus 2.994.227€ for the gas boiler or a saving of 1.740.422€ or 58% !

The CO2 emission has been reduced from 11.777 tons for the gas boiler to 6.966 tons for the heat pump or reduction of 4.811 ton or 40% !




Table 5.

### AND NEXT

The following district heating project is under construction but shows again the importance of the huge savings possible to realize. This is a 90 GWh heat pump installation on yearbasis based on the seasonal loads available per hour per season.

Table nr 6 shows the design details per heat pump set each containing 2 pieces NH3 high pressure heat pump compressors and 2 pieces of NH3 heat source compressors. In total 6 sets are needed. The hot water output temperature is 80°C with total around 13.800 kW and the heat source is taken from a water purification station. In the high season the water is cooled from 15°C to 5°C with total around 10.000 kW per hour. Figure 4 gives a view on the heat pump package with 4 compressors each. The NH3 charge is 240 kg per package what corresponds with approx.100 g/kW heat output.




Table 6.






Figure 4.

In table nr 7 an overview is given of the heat production of 1 year operation. The seasons are shown in the first column with 3 months operation for high season, 6 months operation for mid season and 3 months for the low season. The next columns show the running hours per season of each compressor and the total running hours of 8.640. The total heating capacity amounts to 91.755 MWh per year and the total electrical power input amounts to 25.708 MWh corresponding with a COP-h of 3,57.

HEAT PRODUCTION ON YEARLY BASIS							
season	month	sum	heating		BKW		COPh
	qty	hrs	per hour kW	total MWh	per hour kW	total MWh	
high	3	2160	12098	26132	3457	7467	3,50
mid	6	4320	12722	54959	3524	15224	3,61
low	3	2160	4937	10664	1397	3018	3,53
total	12	8640		91755		25708	3,57

Table 7.

The operation savings of this heat pumps compared to conventional gas boilers are listed up in table 8. The yearly hot water production of the heat pump is increased with 10% in case of the gas boiler. The electrical power finally to be paid is obtained by applying 20% losses resulting to 2,85. The yearly energy consumption in case of the heatpumps is 32.194 MWh while 101.950 MWh for the gas boiler representing a saving of 69.755 MWh or 68% !

The energy prices for the plant are amounting to 65 €/MWh for electricity and 44 €/MWh for gas which results in an energy cost of 2.092.650€ for the heat pump versus 4.485.782€ for the gas boiler or a saving of 2.393.107€ or 53% !

The CO<sub>2</sub> emission has been reduced from 18.045 tons for the gas boiler to 16.097 tons for the heat pump or reduction of 1.948 ton or 11% !




Table 8.

## SUMMARY

To highlight once more the results obtained by applying NH3 heat pump installations against using conventional gas boilers :

1<sup>st</sup> a 60 GWh/yr HP plant to produce 85°C district heating water by using waste heat from flue gas

2<sup>nd</sup> a 92 GWh/yr HP plant to produce 80°C district heating water by using water purification station as heat source

an input energy reduction was achieved of 80 to 68%

an energy cost saving was herewith achieved of 58 to 53%

a CO2 emission reduction was achieved of 40 to 11%.

SUMMARY			SAVINGS / YR		
HEAT SOURCE	HOT WATER T°	OUTPUT INPUT ENERGY MWh/yr COP-h.el	ENERGY MWhr %	ENERGY € %	CO2 tons %
FLUE GAS	85	60.000 14.000	52.600	1.740.000	4.800
50°C		4,30	80	58	40
WATER STATION	80	92.000 32.000	69.800	2.393.100	2.000
5->13°C		2,85	68	53	11